



Document Name  
**MODBUS POINTS LIST**  
 Unit Type  
**LC/LV For Program Version 3.x.x**

| * Logical Address      | Description                | Input Registers 3x | Data Format    | Comments                                   |
|------------------------|----------------------------|--------------------|----------------|--|
| 00001 LSW<br>00002 MSW | Suction Pressure           | Read Only          | 32-bit Float   | Linear from 0.0 to 250.0 psig.             |
| 00003 LSW<br>00004 MSW | Discharge Pressure         | Read Only          | 32-bit Float   | Linear from 0.0 to 650.0 psig.             |
| 00005 LSW<br>00006 MSW | Zone Air Relative Humidity | Read Only          | 32-bit Float   | Linear from 0.0 to 100.0 %.                |
| 00007 LSW<br>00008 MSW | Zone Air Temperature       | Read Only          | 32-bit Float   | Linear from -40.0°F to 140.0 °F.           |
| 00009 LSW<br>00010 MSW | Pool Inlet Temperature     | Read Only          | 32-bit Float   | Linear from -58.0 to 212.0 °F.             |
| 00011 LSW<br>00012 MSW | Pool Outlet Temperature    | Read Only          | 32-bit Float   | Linear from -58.0 to 212.0 °F.             |
| 00013 LSW<br>00014 MSW | Partial Pool Temperature   | Read Only          | 32-bit Float   | Linear from -58.0 to 212.0 °F.             |
| 00015 LSW<br>00016 MSW | Refrigerant Superheat      | Read Only          | 32-bit Float   | Linear from -58.0 to 212.0 °F.             |
| 00017 LSW<br>00018 MSW | Air Heating Command        | Read Only          | 32-bit Float   | Linear from -58.0 to 212.0 °F.             |
| 00019 LSW<br>00020 MSW | Bypass Damper Command      | Read Only          | 32-bit Float   | Linear from 0.0 to 100.0 %.                |
| 00021 LSW<br>00022 MSW | O/A Damper Command         | Read Only          | 32-bit Float   | Linear from 0.0 to 100.0 %.                |
| 00023                  | Unit Status                | Read Only          | 16-bit Integer | For code definitions, see the table below. |

| * Logical Address      | Description                             | Holding Registers 4x | Data Format  | Comments                       |
|------------------------|---|----------------------|--------------|--------------------------------|
| 00024 LSW<br>00025 MSW | Zone Relative Humidity Setpoint         | Read/Write           | 32-bit Float | Settable from 0.0 to 100.0 %.  |
| 00026 LSW<br>00027 MSW | Zone Air Temperature Setpoint           | Read/Write           | 32-bit Float | Settable from 65.0 to 99.9 °F. |
| 00028 LSW<br>00029 MSW | Pool Water Temperature Setpoint         | Read/Write           | 32-bit Float | Settable from 0.0 to 99.9 °F.  |
| 00030 LSW<br>00031 MSW | Partial Pool Water Temperature Setpoint | Read/Write           | 32-bit Float | Settable from 0.0 to 99.9 °F.  |

| * Logical Address | Description            | Coils 0x   | Data Format | Comments   |
|-------------------|------------------------|------------|-------------|--|
| 00001             | Network Remote On/Off  | Read/Write | Boolean     | Set 0 for Unit On, Set 1for Unit Off. This action needs to be enabled at the controller before it can be used. |
| 00002             | Network Occupied Input | Read/Write | Boolean     | Set 0 for Network Unoccupied request. Set 1 for Network Occupancy Request.                                     |
| 00003             | Remote Reset           | Read/Write | Boolean     | Set 1to Remote Reset the Unit. 0 is reset after 5 seconds.   |
| 00004             | Roof / Wall Switch     | Read/Write | Boolean     | Set 1 when Roof is open. Set 0 when Roof is closed. This action requires setup in the Service Menu.            |

| * Logical Address | Description          | Discrete Inputs 1x | Data Format | Comments  |
|-------------------|----------------------|--------------------|-------------|---|
| 00005             | Supply Fan           | Read Only          | Boolean     | State of Supply Fan, 0 = Off, 1 = On.                   |
| 00006             | Compressor           | Read Only          | Boolean     | State of Compressor, 0 = Off, 1 = On.                   |
| 00007             | Pool Water Pump      | Read Only          | Boolean     | State of Pool Pump Output. 0 = Off, 1 = On.             |
| 00008             | Auxiliary Pool Heat  | Read Only          | Boolean     | State of Auxiliary Pool Heat Required. 0 = Off, 1 = On. |
| 00009             | Air Heating Required | Read Only          | Boolean     | State of Air Heat Requirement. 0 = Off, 1 = On.         |



Document Name  
**MODBUS POINTS LIST**  
 Unit Type  
**LC/LV For Program Version 3.x.x**

| * Logical Address | Description                | Discrete Inputs 1x | Data Format | Comments  |
|-------------------|----------------------------|--------------------|-------------|---|
| 00010             | Tower Water Pump           | Read Only          | Boolean     | State of Tower Water Pump Output. 0 = Off, 1 = On.            |
| 00011             | Occupied                   | Read Only          | Boolean     | Confirmation of Occupied Status. 0 = Unoccupied, 1 = Occupied |
| 00012             | Alarm Active               | Read Only          | Boolean     | Confirmation of Active Alarm. 1 = Alarm, 0 = Normal.          |
| 00013             | Retain Memory Alarm        | Read Only          | Boolean     | Controller Retain Memory Error, 0 = Normal, 1 = Alarm.        |
| 00014             | Retain Memory Write Alarm  | Read Only          | Boolean     | Controller Retain Memory Write Error, 0 = Normal, 1 = Alarm.  |
| 00015             | Blower Overload Alarm      | Read Only          | Boolean     | Blower Overload Alarm, 0 = Normal, 1 = Alarm.                 |
| 00016             | Compressor Overload Alarm  | Read Only          | Boolean     | Compressor Overload Alarm, 0 = Normal, 1 = Alarm.             |
| 00017             | Smoke Alarm Active         | Read Only          | Boolean     | Smoke Alarm, 0 = Normal, 1 = Alarm.                           |
| 00018             | Suction Pressure Alarm     | Read Only          | Boolean     | Low Suction Pressure, 0 = Normal, 1 = Alarm.                  |
| 00019             | Discharge Pressure Alarm   | Read Only          | Boolean     | High Discharge Pressure, 0 = Normal, 1 = Alarm.               |
| 00020             | Sensor Communication Alarm | Read Only          | Boolean     | Zone Sensor Communication Fault, 0 = Normal, 1 = Alarm.       |
| 00021             | c.PCOe Configuration Alarm | Read Only          | Boolean     | Expansion Module Configuration Fault, 0 = Normal, 1 = Alarm.  |
| 00022             | c.PCOe Communication Alarm | Read Only          | Boolean     | Expansion Module Communication Fault, 0 = Normal, 1 = Alarm.  |
| 00023             | Low Voltage Alarm          | Read Only          | Boolean     | Low System Voltage Fault, 0 = Normal, 1 = Alarm.              |
| 00024             | Clogged Filter Alarm       | Read Only          | Boolean     | Clogged Filter Fault, 0 = Normal, 1 = Alarm.                  |

\* All coil and holding register addresses are in PLC style base 0 notation. If base 1 notation is required, add 1 to the logical address number.

| CODE | UNIT STATUS                    |
|------|--------------------------------|
| 0    | Unit Off /Zone Satisfied       |
| 1    | Heating Required               |
| 2    | Cooling Required               |
| 3    | Dehumidification Required      |
| 4    | Dehum and Cooling Required     |
| 5    | Dehum and Heating Required     |
| 6    | Low Suction Pressure Condition |
| 7    | Low Air Flow Condition         |
| 8    | Low DHU Temperature            |
| 9    | High DHU Temperature           |
| 10   | System Switch is Off           |

| Revision (Rev.) History |  |            |          |          |
|-------------------------|--|------------|----------|----------|
| Rev.                    | Description                              | Date       | Initials | ECN #    |
| 00                      | Initial Release                          | 11/15/2017 | MTW      | EC-10328 |
| 01                      | Added Low Voltage and Filter Alarm       | 1/31/2018  | MTW      | EC-10360 |
| 02                      | Unit Status codes 4 and 5 were inverted. | 5/23/2019  | MTW      | EC-10484 |